

02/12/2019

Wonderware System Platform Vulnerability – Potential for Unauthorized Access to Credentials

A recent ICS-Cert advisement (ICSA-19-029-03) warns of a vulnerability in System Platform 2017 Update 2 and all previous versions. [Read the ICS-Cert bulletin](#)

Wonderware System Platform uses an ArcestrA network user account for authentication of system processes and inter-node communications. A user with low privileges could make use of an API to obtain the credentials for this account. [Read the AVEVA security bulletin](#)

System Platform 2017 Update 3 mitigates this vulnerability. Wonderware recommends users upgrade as soon as possible. System Platform 2017 Update 3 no longer requires the ArcestrA network user account to be a local administrative level account, nor does it require SQL Server 'sysadmin' permissions after installation is complete. [Download System Platform 2017 Update 3](#)



Need Tech Support? Call our Hotline.

Troubleshooting telephone/email support is free to our customers during normal business hours: from 8:00 AM to 5:00 PM CST. If additional support services are required, our team can provide support for your specific situation.

The Tech Support Hotline number is **913-254-5000**.

Press 1 for Software, 2 for Hardware, or 3 for Unsure

Get Support from Wonderware

Customers on support have access to the [Customer First portal](#). From license activation and tech notes to software download and a compatibility matrix, don't miss the latest from Wonderware on how to keep your software operating at its peak performance.

[Not on Support? Contact us.](#)